



County of Albemarle
Community Development Department

William D. Fritz, AICP
bfritz@albemarle.org
Telephone: (434) 296-5832 ext. 3242

To: Albemarle County Board of Supervisors
From: William Fritz, AICP, Development Process Manager
RE: SE2024-23 Crozet Wastewater Pump Station 3
Date: November 6, 2024
Parcel ID: 05700-00-00-079A1
Magisterial District: Samuel Miller
School Districts: Murray, Henley, Western Albemarle
Zoning District: RA, Rural Areas, EC, Entrance Corridor Overlay District

Summary of Special Exception:

The applicant is proposing to install a 2,000 gallon fuel storage tank approximately 25 feet from a lot line. The ordinance requires fuel storage tanks in excess of 600 gallons to be set back 100 feet from any lot line.

Staff Recommendation:

Staff recommends that the Board adopt the resolution (Attachment E) to approve the proposed special exception to allow a fuel storage tank to be located less than 100 feet from any lot line.

Attachments:

- A. Staff Analysis
- B. Applicant's Request
- C. Adopted Code
- D. Surrounding Location Map
- E. Proposed Resolution